



Jim Doyle, Governor  
Jack L. Fischer, A.I.A., Secretary

August 11, 2008

ALPHA GENERAL SERVICES, INC.  
RICHARD J LAPADULA  
PO BOX 3331  
SEBRING FL 33871-3331

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: ALPHA GENERAL SERVICES, INC.  
Product Name: SEPTIC/MICROFAST® 0.5, SEPTIC/MICROFAST® 0.75, SEPTIC/MICROFAST® 0.9  
Model Number(s): 1350 GAL. SEPTIC, FIBERGLASS OPTION 2-COMPARTMENT  
[MICROFAST® 0.5, MICROFAST® 0.57 OR MICROFAST® 0.9]  
[MAX. DEPTH OF BURY 2 FT.]  
Product File No: 20080211

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 500 gallons per day.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov